



1 LIFE SAFETY SYSTEMS - SECOND FLOOR
 SCALE: 1: 100

FIRE ALARM GENERAL NOTES:

1. UNITS OF MEASUREMENT ARE IN MM UNLESS OTHERWISE NOTED.
2. THIS DRAWING SHALL BE READ IN CONJUNCTION WITH THE ARCHITECTURAL CEILING PLANS, MECHANICAL AND STRUCTURAL DRAWINGS.
3. DIVISION 26 TO COORDINATE WITH THE MECHANICAL AND ARCHITECTURAL CONTRACTOR FOR THE LAYOUT OF FIRE ALARM DEVICES AT SITE.
4. REFER TO FIRE ALARM DEVICES INSTALLATION INSTRUCTIONS FOR MORE INFORMATION AND RECOMMENDATIONS.
5. ALL FIRE ALARM WIRING, BOXES AND CONDUITS ABOVE CEILING SHALL BE FULLY SUPPORTED AND CONNECTED WITH APPLICABLE CONNECTORS, ADAPTERS AND FITTINGS.
6. ALL WIRING TO MAINTAIN ALLOWABLE CLEARANCE WITH OTHER SERVICES.
7. REFER TO RISER DIAGRAM FOR FIRE ALARM ZONING AND DISTRIBUTION.
8. ALL FIRE ALARM DEVICES PROVIDED WITH APPLICABLE HARDWARE ACCESSORIES AS REQUIRED.
9. ALL ABOVE REFLECTIVE CEILING PLAN FIRE ALARM DEVICES TO BE INDEPENDENTLY SUPPORTED FROM THE FALSE CEILING STRUCTURE.
10. OBSERVE ALL FIRE ALARM DEVICES CLEARANCE FROM THE SIDE WALL TO BE NOT LESS THAN 500MM AND ADJUST ACCORDINGLY.
11. ALL FIRE ALARM WIRES TO BE IN 21MM DIA. CONDUIT.
12. SCHEDULING OF WORK IN EXISTING BUILDING SHALL BE COORDINATED WITH OWNER (THROUGH THE GENERAL CONTRACTOR) AND ARRANGED TO MINIMIZE DISRUPTIONS TO OWNERS OPERATION DURING NORMAL WORKING HOURS. ANY SHUTDOWN OR INTERRUPTION TO SYSTEM SHALL BE AT TIMES ACCEPTABLE AND APPROVED BY OWNER.

Drawings and specifications, as instruments of service are the property of the architect. The copyright in the same being reserved to Verne Reimer Architecture Incorporated. No reproduction may be made without the permission of the architect and when made, must bear his name. All prints to be returned to the architect.
 The general contractor and/or project manager shall verify dimensions and data noted herein with conditions on the site and is held responsible for reporting any discrepancy to the architect for adjustment. Do not trace the drawings.

CONSULTANTS

wsp
 1000 BUFFALO PLACE
 WINNIPEG, MANITOBA
 CANADA R2T 1B8
 PHONE 204-774-6800
 WWW.WSPGROUP.COM

NOT FOR CONSTRUCTION

REV	DATE	DESCRIPTION
15	02/06/022	ISSUED FOR ADDENDUM
14	12/05/022	ISSUED FOR CONSTRUCTION
13	29/04/022	ISSUED FOR PRE-TENDER CHECK SET
12	26/03/021	ISSUED FOR CLIENT REVIEW (100%)
11	24/02/021	ISSUED FOR REVIEW
10	17/02/021	ISSUED FOR CLIENT REVIEW (100%)
9	12/02/021	ISSUED FOR COORDINATION
8	05/02/021	ISSUED FOR COORDINATION
7	22/01/021	ISSUED FOR CLASS A ESTIMATE
6	15/01/021	ISSUED FOR COORDINATION
5	12/06/020	ISSUED FOR 95% REVIEW
4	03/11/020	ISSUED FOR OWNER REVIEW
3	03/05/020	ISSUED FOR REVIEW
2	12/20/019	ISSUED FOR REVIEW
1	11/29/019	ISSUED FOR 50% REVIEW

CLIENT
 CITY OF IQALUIT
 OPERATIONS CENTRE
 1549 FEDERAL ROAD
 IQALUIT, NUNAVUT
 X0A 0H0
 CLIENT PROJECT NO. 820837

TITLE:
 LIFE SAFETY SYSTEMS
 SECOND FLOOR
 SCALE: 1: 100
 PROJECT NUMBER: 2019.00800
 DRAWN BY: ABL

EY20