



Project: 720062 – WTP Laboratory And Washroom Renovations RFQ

Addendum No.	2	No. of Pages:	2
Date:	31-May-2022	Doc. No.	P7201-1063947821-19 (1.0)

The following change(s) in the Tender Documents are effective immediately.
This Addendum forms part of the Contract Documents.

ITEM	DESCRIPTION	ACTION
------	-------------	--------

Question 1:

Please provide information pertaining to the installation of a water sample port, as per scope of work Item 1.D

.1 For the Laboratory:

- .a Remove existing flooring, supply and install new flooring suitable for Industrial and Laboratory use.
- .b Supply and install a Stainless Steel 316 Countertop and dual sinks. (Approximate 12-foot piece of stainless steel).
- .c Remove and dispose existing overhead cupboards, counter, and below the counter cabinets. Counter cabinets will not be replaced.
- .d Install a Water Sample port. Details to be provided by the Utilidor Supervisor on site.
- .e Supply and install two cabinets to the right side of the (new) stainless counter.
- .f Perform all patchwork and paint the walls with base coat and two coats of white paint.

Response 1:

There will be at least 2 water valved sampling ports that will be directly above the sink. Refer to the enclosed picture.



Distribution: All Bidders
File