



Project:	2023-RFT-045 LTWP – Water Distribution Upgrades – Federal Road Watermain Extension		
Addendum No.:	01	No. of Pages	4
Date:	March 17, 2022	Doc. No:	P7201-718885162-134 (2.0)

The following change(s) in the Tender Documents are effective immediately.
This Addendum forms part of the Contract Documents.

ITEM	DESCRIPTION	ACTION
------	-------------	--------

Question 1.1:

Please provide the diameter of the service laterals for the supply and return lines of each building in this tender package. We will need to know this information in order to accurately estimate the cost of the underground infrastructure required to connect each unit to the new water lines. This information is also necessary to estimate the cost of the temporary water system.

Response 1.1:

There is no service lateral installation included as part of the scope of work for this project.

Question 1.2:

Note 11 from drawing DE-01 is indicating “transition coupling” and the point 2.1.9 from section 33 05 14 – Access Vault is indicating that:

- .9 Flexible Couplings
 - .1 For all flexible couplings to be installed externally on all new Access Vault Watermain/Service connections, the standard of acceptance shall be Victaulic’s 257 Dynamic Movement joint or approved equivalent. All flexible couplings shall be insulated and wrapped upon installation.

Are we to understand that the transition couplings from drawing DE01 are considered as Victaulic 257 Dynamic Movement joint and are to be installed at the exterior of AV2 for the section towards existing AV1 and AV3 only?

Response 1.2:

There are no flexible couplings included in the scope of work for this project. Point 2.1.9 from specification section 33 05 14 is to be omitted. The “transition coupling” illustrated at the 300x200 reducer connection to existing 200mm diameter pipe on drawing DE01 was intended to depict an electrofusion coupling.

Addendum No. 1:

Question 1.3:

On the Appendix B – Cost submission form it is indicated at item 13 that the road and driveway reinstatement to be 200mm of Granular A and 400mm of Granular B but in the specs section 31.23.33.01 point 3.15.2 it is indicated that “In areas of granular road structure, the road granular shall be reinstated at 300mm Gran B and 100mm Grand A”. Could you please confirm which is correct? Could you also confirm that the granular A and B thickness are applicable to both gravel driveways and cold patch driveways?

Response 1.3:

Reinstatement to be 300mm Gran B and 100mm Gran A for both gravel driveways and cold patch driveways.

Question 1.4:

Could you please confirm in which case the 4H:1V transition slope indicated on detail 1 from drawing DE-04 is applicable? Is it applicable to both excavations of culvert and water lines when there is a cold patch to be installed? It seems like a 4H:1V slope would create more cold patch area than was indicated on drawings and at item 17 on the Appendix B- Cost submission form.

Response 1.4:

3H:1V transition slope is acceptable for all excavations.

Question 1.5:

Would the City accept a substantial completion date of November 17th, 2023? The current lead time on material for the access vault does not allow to confirm all the access vaults can be received on the second sealift to complete the work in time for the substantial completion of October 27th, 2023.

Response 1.5:

Yes, the City accepts the extension of the substantial completion date from October 27th, 2023 to November 17th, 2023. However, the works are to be planned and executed by the Contractor in as short a time as is practically feasible. Please refer to the updated Contract Timelines below:

ACTION	DATE
Opening Date for RFT	March 1, 2023
Deadline for Submitting Inquiries	March 15, 2023 at 15:00h EST
Deadline for Inquiry Response	March 18, 2023
Closing Date for RFT	March 22, 2023 at 15:00h EST
Public Opening	March 22, 2023 at 16:00h EST
Approvals	April 11, 2023
Contract Award Date	April 14, 2023
Project Kick-Off	April 20, 2023
Substantial Performance	November 17, 2023
Completion	December 5, 2023
Warranty Start Date	November 17, 2023
Warranty End Date	November 17, 2024

Addendum No. 1:

Question 1.6:

Point 2.5 from Part IV – Supplementary Conditions is indicating that “ The successful proponent will be required to report annually on Community Employment Benefits for a minimum (3) federal Target Groups to be determined by the City upon project award “

-Could you please confirm this section is applicable to this contract ?

-The table attached is only referring to one target group (Apprentices). There seems to be missing a second page. Could you please provide the second page ?

Response 1.6:

Yes, this section is applicable to this contract. The missing page 3 of 3 from section IV Supplementary Conditions is enclosed for reference. The Contractor awarded with the contract will be required to track hours related to the three Federal Target Groups below:

- a) Indigenous People**
- b) Women, and**
- c) Persons with Disabilities**

Question 1.7:

Can the missing page be provided, see page 95 of section IV of the Supplementary Conditions it notes page 2 of 3.

Response 1.7:

The missing page 3 of 3 from section IV Supplementary Conditions is enclosed for reference.

Colliers Project Leaders Inc.

Distribution: All Bidders
File

Indigenous Peoples	Self-identified.	Total Hours Worked for Individual Target Group
Women	Self-identified.	Total Hours Worked for Individual Target Group
Persons with Disabilities	Self-identified.	Total Hours Worked for Individual Target Group
Veterans	Any former member of the Canadian Armed Forces who successfully underwent basic training and is honourably released.	Total Hours Worked for Individual Target Group
Youth	Based on each province/territory definition.	Total Hours Worked for Individual Target Group
Recent Immigrants	Person who obtained a landed immigrant or permanent resident status up to five years prior to a given census year. In the 2016 Census, this period is January 1, 2011, to May 10, 2016.	Total Hours Worked for Individual Target Group
Small Enterprise	Small businesses are businesses with 1 to 99 employees	Contract Value
Medium enterprise	Medium-sized businesses are businesses with 100 to 499 employees.	Contract Value
Social Enterprise	Revenue-generating organizations whose objective is to have a social impact.	Contract Value

END OF SECTION