



ADDENDUM

Project:	Iqaluit West 40 Landfill Site Access Improvements	Addendum No.: 4
		1 Pages
		May 1, 2019
		820973-0066(4.0)

The following change(s) in the RFP Documents are effective immediately.
This Addendum forms part of the RFP Documents.

ITEM	DESCRIPTION	ACTION
1.1	Clarification Questions	
1.1.1	Q1: Who is responsible for the power connection to the seasonal trailer? A1: The Contractor must provide the mast and weather head and utility metering provisions as required by Qulliq Energy Corporation. Qulliq will bring in the transformer and power to the building.	
1.1.2	Q2: Please provide a site electrical plan showing intended routing of power. A2: An electrical plan will be provided to the successful contractor after award. A drawing is currently not available and will be dependent on QEC.	
	Colliers Project Leaders Inc. Date: May 1, 2019 Distribution: All Bidders	