ADDENDUM

Project:	Trigram Reheat Station Relocation (2025-RFT-093)	Addendum No.: 2
		No. of Pages: 1
		Date: May 5, 2025
		Doc. No. P7201-950302569-968(1.0)

The following change(s) in the Tender Documents are effective immediately.
This Addendum forms part of the Contract Documents.

ITEM	DESCRIPTION	ACTION

Q2.1
We were hoping to use our Canadian supplier **Current** for the instrumentation. First, we would like to propose the **Imag100** for the **magmeters**, we can build this to have .2% accuracy. For **pressure transmitter** we would like to use the **IBar800.**

R2.1
Yes, alternative suppliers and manufacturers will be considered, as long as they meet or exceed the existing specification requirements. Final design must be reviewed during the shop drawing stage to confirm compliance with the specifications provided.

Colliers Project Leaders Inc.

Distribution: All Bidders
File